

Fire Plan Review Submittal Requirements

Permit Application

Minimum Fire Sprinkler, Fire Alarm and Fire Suppression Hood System submittal requirements.

_____ Complete Fire Permit Application (with contact information & Email address)

_____ Copy of State of Texas License, or FPE as applicable

Fire Sprinkler Submittal Requirements

Comply with NFPA 13, 13R or 13D as applicable

_____ Plans with stamp and signature of RME-G meeting requirements of NFPA 13, 13R, 13D.

_____ Cut Sheets (technical data documentation)

_____ Hydraulic Calculations

_____ Hydrant Flow Data performed within 6 months of design of system

Fire Alarm Submittal Requirements

_____ Comply with NFPA 72

_____ Plans with stamp and signature of a person holding a fire alarm planning superintendent license or a residential fire alarm superintendent license, as applicable, or a Texas registered professional engineer

_____ Cut Sheets

_____ Battery Calculations

Fire Hood Suppression Systems or Alternative Fire Suppression System

_____ Plans with stamp and signature of designer, fixed fire extinguisher systems other than pre-engineered systems must be planned, installed, or serviced by a Type PL licensee or professional engineer.

_____ Cut Sheets

PLANS CAN BE SUBMITTED ELECTRONICALLY – EMAIL TO fwplanreview@us.bureauveritas.com

One copy of all submittal documents required.